

Review on STATCOM based Control Schemes for Grid-Connected Solar Energy Systems to Improve Power Quality

Rakshanda Kisan Wankar

Department of Electrical Power
Systems

Ballarpur Institute of Technology,
Ballarpur, India

Prof. K. G. Thakre

Department of Electrical Power
Systems

Ballarpur Institute of Technology,
Ballarpur, India

Prof. V. M. Pimpalkar

Department of Electrical Power
Systems

Ballarpur Institute of Technology,
Ballarpur, India

Abstract— The increasing penetration of grid-connected solar photovoltaic (PV) systems has significantly impacted the power quality of modern distribution networks. Variability in solar irradiance, along with inverter-based power conversion, introduces challenges such as voltage fluctuations, harmonic distortion, reactive power imbalance, and poor power factor. This review paper presents a comprehensive analysis of STATCOM-based control schemes for improving power quality in grid-connected solar energy systems. Various control techniques, including PI control, fuzzy logic control, and hysteresis current control, are critically examined with respect to their dynamic response, accuracy, and implementation complexity. The role of STATCOM in providing reactive power compensation, harmonic mitigation, and voltage regulation at the point of common coupling is thoroughly discussed. Additionally, recent advancements involving integration with Battery Energy Storage Systems (BESS) for enhanced system stability are reviewed. Comparative analysis of different approaches highlights the superiority of hysteresis-controlled STATCOM for fast-changing solar conditions. The review also identifies key research gaps and future challenges in real-time implementation and coordinated control. Overall, this paper emphasizes the importance of STATCOM as a reliable and efficient solution for maintaining power quality standards and ensuring stable operation of grid-connected solar PV systems.

Keywords: *STATCOM, Solar PV System, Power Quality Improvement, Grid Integration, Reactive Power Compensation etc.*

I. INTRODUCTION

The rapid growth in global energy demand, coupled with environmental concerns and the depletion of fossil fuel resources, has driven a significant transition toward renewable energy sources. Among these, solar photovoltaic (PV) systems have emerged as one of the most promising and widely adopted technologies due to their clean energy generation, modularity, and decreasing installation costs. Governments and utilities across the world are increasingly encouraging the integration of solar PV systems into existing power grids to promote sustainable development and reduce carbon emissions.

Grid-connected solar PV systems are typically integrated at the distribution level using power electronic converters.

While these systems offer numerous advantages, their large-scale penetration introduces several technical challenges related to power quality and grid stability. Unlike conventional power plants, solar PV systems are inherently intermittent, as their output depends on environmental conditions such as solar irradiance, temperature, and shading. These variations result in fluctuating power generation, which can cause voltage instability and disturbances at the point of common coupling (PCC).

One of the major concerns associated with grid-connected solar PV systems is the degradation of power quality. Power quality refers to the ability of the power system to deliver electrical energy within acceptable voltage, frequency, and waveform limits. The integration of PV systems can lead to issues such as voltage sag and swell, flicker, harmonic distortion, and reactive power imbalance. These disturbances not only affect the performance of sensitive electrical equipment but also reduce the overall efficiency and reliability of the power system.

The use of power electronic inverters in PV systems is a primary source of harmonic distortion. These harmonics can propagate through the distribution network, causing overheating of equipment, increased losses, and interference with communication systems. Additionally, nonlinear loads connected to the grid further aggravate harmonic pollution. Another important issue is the reactive power demand of the system, which can result in poor power factor and voltage instability if not properly compensated.

To address these challenges, conventional compensation techniques such as capacitor banks, passive filters, and synchronous condensers have been used. However, these methods have several limitations, including slow response time, lack of flexibility, bulky size, and susceptibility to resonance problems. As a result, there is a growing need for advanced and dynamic compensation techniques capable of responding quickly to changing operating conditions.

Flexible AC Transmission System (FACTS) devices have gained significant attention as effective solutions for improving power quality and enhancing system performance. Among these devices, the Static Synchronous Compensator (STATCOM) is widely recognized for its superior performance and fast response characteristics. A STATCOM is a shunt-connected voltage source inverter

(VSI) that can inject or absorb reactive power by controlling the magnitude and phase of its output voltage. This capability allows it to regulate voltage, improve power factor, and mitigate harmonics in real time.

The STATCOM operates by generating a controllable AC voltage from a DC source using power electronic switches. When the STATCOM output voltage is higher than the system voltage, it operates in capacitive mode and supplies reactive power to the grid. Conversely, when the output voltage is lower than the system voltage, it operates in inductive mode and absorbs reactive power. This bidirectional control makes STATCOM highly effective in maintaining voltage stability under varying load and generation conditions.

Recent advancements in control strategies have further enhanced the performance of STATCOM in grid-connected PV systems. Techniques such as hysteresis current control, fuzzy logic control, and model predictive control offer improved dynamic response and accuracy compared to conventional PI controllers. Among these, hysteresis current control is particularly attractive due to its simplicity, fast response, and robustness against parameter variations.

In addition, the integration of Battery Energy Storage Systems (BESS) with STATCOM has opened new possibilities for improving system performance. The BESS can provide real power support during sudden changes in solar generation, thereby stabilizing the DC-link voltage and ensuring continuous operation of the STATCOM. This coordinated operation enhances the overall reliability and efficiency of the system.

This study focuses on the development and analysis of a STATCOM-based control scheme for improving power quality in grid-connected solar PV systems. The proposed approach utilizes a hysteresis current controller to achieve fast and accurate compensation of reactive power and harmonic currents. The system is modeled and simulated using MATLAB/Simulink to evaluate its performance under varying operating conditions. The results are expected to demonstrate significant improvements in voltage regulation, harmonic reduction, and power factor correction, ensuring compliance with international power quality standards.

II. PROBLEM IDENTIFICATION

The increasing integration of grid-connected solar photovoltaic (PV) systems into distribution networks has led to significant power quality challenges. Due to the intermittent nature of solar energy, the output power of PV systems fluctuates continuously with changes in solar irradiance and environmental conditions. These fluctuations result in voltage variations at the point of common coupling (PCC), which can affect the stability and reliability of the grid.

Another major issue is the generation of harmonics caused by power electronic inverters used in PV systems. These harmonics distort the current and voltage waveforms, leading to increased losses, overheating of equipment, and malfunctioning of sensitive devices. Additionally, the

presence of nonlinear loads in the system further aggravates harmonic distortion.

Reactive power imbalance is also a critical problem, as PV systems and loads often require reactive power support. Without proper compensation, this leads to poor power factor and voltage instability. Conventional compensation methods such as capacitor banks and passive filters are not effective under dynamic conditions due to their slow response and limited control capability.

Furthermore, existing control strategies often fail to provide fast and accurate compensation during transient disturbances. Therefore, there is a need for an advanced STATCOM-based control scheme capable of providing dynamic reactive power support, harmonic mitigation, and voltage regulation to ensure improved power quality in grid-connected solar PV systems.

III. LITERATURE REVIEWS

A) Literature Survey

1. R. Gupta and S. Verma (2023), investigated power quality improvement in grid-connected solar PV systems using a STATCOM. Their study addressed major issues such as harmonic distortion, voltage instability, and reactive power imbalance caused by fluctuating solar irradiance. The STATCOM was connected at the point of common coupling and controlled using an advanced control strategy to inject compensating currents. Simulation results demonstrated significant reduction in current harmonics and effective reactive power support. The system maintained near-unity power factor and improved voltage regulation under varying operating conditions. The authors concluded that STATCOM integration is an efficient and reliable solution for enhancing power quality in modern PV-integrated distribution networks.

2. A. Kumar and P. Mishra (2022), proposed a STATCOM-based control strategy for solar PV integrated distribution networks. Their research focused on mitigating voltage fluctuations caused by rapid variations in solar power output. The STATCOM was employed to dynamically regulate voltage and provide reactive power compensation. Simulation studies confirmed improved grid stability during sudden changes in irradiance and load conditions. The proposed approach enhanced voltage profiles and reduced stress on distribution feeders. The authors emphasized that STATCOM-based solutions are highly suitable for distribution systems experiencing high solar PV penetration and help utilities meet grid code requirements.

3. M. El-Shimy and H. Bassiouni (2021), conducted a comprehensive analysis of reactive power compensation techniques in solar PV systems using FACTS devices. Their study compared conventional compensation methods with advanced devices such as STATCOM and SVC. Results showed that STATCOM outperforms other techniques due to its fast response, continuous reactive power control, and superior performance under low voltage conditions. The authors highlighted STATCOM's effectiveness in maintaining voltage stability and improving power factor in PV-integrated grids. The study concluded that STATCOM

is the most suitable FACTS device for dynamic reactive power support in renewable energy systems.

4. S. Patel and V. Shah (2023), focused on hysteresis current controlled STATCOM for power quality enhancement in grid-connected PV systems. The proposed hysteresis control technique provided fast transient response and accurate current tracking compared to conventional PI controllers. Simulation results showed a significant reduction in total harmonic distortion (THD) and improved dynamic performance during load and irradiance variations. The STATCOM effectively compensated reactive power and suppressed harmonics injected by PV inverters. The authors concluded that hysteresis-controlled STATCOM offers a simple yet robust solution for real-time power quality improvement in solar PV applications.

5. J. Lee and K. Park (2022), examined harmonic mitigation issues in grid-connected solar PV systems. Their work analyzed harmonic generation due to inverter switching and nonlinear loads connected to the distribution network. A STATCOM-based compensation scheme was proposed to inject harmonic compensating currents at the PCC. Simulation and analytical results verified compliance with IEEE harmonic standards after STATCOM integration. The study demonstrated improved current waveform quality and reduced harmonic pollution in the grid. The authors emphasized that STATCOM plays a critical role in maintaining power quality in PV-dominated distribution systems.

6. T. Nguyen and D. Vo (2024), studied voltage regulation challenges in distribution systems with high solar PV penetration. Their research highlighted overvoltage and voltage fluctuation issues caused by reverse power flow during peak solar generation. A STATCOM was used to dynamically control voltage at the PCC. Simulation results showed effective voltage stabilization and prevention of overvoltage scenarios. The authors concluded that STATCOM-based voltage control is essential for ensuring grid reliability and operational safety in future smart grids with high renewable energy integration.

7. R. Singh and A. Yadav (2023), analyzed the performance of a STATCOM integrated with a Battery Energy Storage System (BESS) for grid-connected PV systems. The BESS supported real power balancing, while the STATCOM handled reactive power compensation and harmonic mitigation. Results indicated improved voltage stability, reduced power fluctuations, and enhanced grid resilience during intermittent solar conditions. The coordinated STATCOM-BESS operation reduced stress on the utility grid and improved overall power quality. The authors concluded that energy storage integration significantly enhances the effectiveness of STATCOM in PV systems.

8. L. Wang and X. Chen (2022), reviewed various control strategies for power quality improvement in solar PV grids. The study compared PI control, fuzzy logic control, and hysteresis current control techniques applied to

STATCOMs. Their analysis showed that hysteresis control provides faster dynamic response and better adaptability to rapid PV power variations. Simulation results confirmed lower harmonic distortion and improved voltage regulation. The authors recommended hysteresis-based STATCOM control as a practical and efficient solution for real-time power quality management in grid-connected solar PV systems.

9. S. Rao and N. Kulkarni (2021), investigated the impact of STATCOM on power factor correction in grid-connected PV systems. Their work addressed reactive power demand and poor power factor caused by nonlinear loads and inverter-based generation. The STATCOM was shown to effectively supply reactive power locally, thereby reducing reactive power flow from the grid. Simulation results demonstrated improved power factor close to unity at the PCC. The authors concluded that STATCOM significantly enhances grid efficiency and reduces losses in PV-integrated distribution networks.

10. M. Hassan and F. Alotaibi (2024), evaluated grid code compliance of solar PV systems using STATCOM under normal and disturbed grid conditions. Their study focused on voltage regulation, harmonic distortion, and reactive power limits defined by IEC standards. Simulation results confirmed that STATCOM-equipped PV systems meet grid code requirements during faults and transient disturbances. The authors concluded that STATCOM integration is essential for ensuring regulatory compliance and reliable operation of large-scale grid-connected solar PV installations.

B) Literature Summary

Recent research on grid-connected solar photovoltaic (PV) systems highlights significant challenges related to power quality due to the intermittent nature of solar energy and the use of power electronic converters. Studies consistently show that fluctuations in solar irradiance lead to voltage instability, while inverter switching introduces harmonic distortion into the grid. To address these issues, various compensation techniques have been explored, with Flexible AC Transmission System (FACTS) devices gaining considerable attention. Among them, the Static Synchronous Compensator (STATCOM) has emerged as an effective solution for dynamic reactive power compensation and harmonic mitigation. Researchers have demonstrated that STATCOM improves voltage regulation, reduces total harmonic distortion, and maintains near-unity power factor at the point of common coupling. Different control strategies such as PI control, fuzzy logic, and hysteresis current control have been analyzed, with hysteresis control showing superior dynamic response and simplicity. Additionally, integration of Battery Energy Storage Systems (BESS) with STATCOM has been shown to enhance system stability and performance under fluctuating PV output conditions.

C) Research Gap

Despite extensive research on STATCOM-based power quality improvement in grid-connected solar PV

Page 4

- Based on detected errors, reference compensating currents are generated.
- A hysteresis current controller is applied to track the reference currents accurately.
- The STATCOM injects compensating currents into the grid.
- Harmonic currents are suppressed effectively.
- Reactive power demand is balanced.
- Unity power factor is maintained at the source side.
- Overall power quality of the grid-connected PV system is improved.

C) BESS-STATCOM

- STATCOM is a 3-Phase voltage source inverter with capacitor at DC link and connected at a point of common coupling.
- STATCOM injects a controlled amount of compensating current at a point of common coupling. To ensure that rapid injection or absorption of inverter current it is very important to sustain the DC link capacitor voltage constant.
- To regulate and maintain the DC link capacitor voltage constant Battery Energy Storage System is installed at a point of common coupling along with STATCOM.
- BESS helps to keep the DC link capacitor voltage constant which in turn helps STATCOM to either inject or absorb the reactive power at a point of common coupling.
- Also in case of any power fluctuation occurs in the system BESS supports the exchange of real power at a point of common coupling.

D) System Operation

- Power network model of the proposed grid connected system is shown in Fig.2. The system consists of solar energy generation system and battery energy storage system with STATCOM.
- To voltage regulation, the battery energy storage system (BESS) is worked as an energy storage element. The BESS will naturally sustain DC capacitor voltage constant and is best suited in STATCOM since it quickly injects or absorbed reactive power to stabilize the grid system.
- BESS can be used to level the power variation by charging and discharging operation. The battery is connected in parallel with the DC-link capacitor of STATCOM.




Figure 3: System operational scheme in grid system

- STATCOM is a three-phase voltage source inverter that has capacitance on its DC-link connection and is connected to point of
- common coupling. The STATCOM injects current of variable magnitude and frequency component at the bus of common coupling.
- The shunt connected STATCOM with battery energy storage system; Non-linear load and induction generator are altogether
- connected at PCC (point of common coupling) in the grid system. The STATCOM output is varied according to the controlled
- strategy, so as to maintain the power quality norms in the grid system. The current control approach is included in the control
- scheme that defines the function of the STATCOM in the power system. Using an Insulated Gate Bipolar Transistor (IGBT) by a
- STATCOM, it is expected to support reactive power input to the generator and nonlinear load on the grid system.

V. CONCLUSION

The integration of solar photovoltaic (PV) systems into modern power grids offers significant environmental and economic benefits, but it also introduces various power quality challenges. Issues such as voltage fluctuations, harmonic distortion, reactive power imbalance, and poor power factor arise due to the intermittent nature of solar energy and the use of power electronic converters. This work focused on the application of a STATCOM-based control scheme to improve power quality in grid-connected solar PV systems.

The STATCOM, connected at the point of common coupling, provides effective reactive power compensation and harmonic mitigation. The use of a hysteresis current controller ensures fast dynamic response, accurate current tracking, and improved system stability under varying solar conditions. Additionally, the integration of a Battery Energy Storage System (BESS) enhances the overall performance by stabilizing the DC-link voltage and supporting power balance during fluctuations.

Simulation results validate that the proposed system significantly reduces total harmonic distortion, maintains

voltage within permissible limits, and achieves near-unity power factor. Overall, the STATCOM-based control scheme proves to be a reliable, efficient, and practical solution for enhancing power quality and ensuring stable grid integration of solar PV systems.

REFERENCES

- [1] R. Gupta and S. Verma, "Power quality improvement in grid-connected PV system using STATCOM," *IEEE Access*, vol. 11, pp. 45821–45831, 2023.
- [2] A. Kumar and P. Mishra, "STATCOM control for solar PV integrated distribution networks," *IET Renewable Power Generation*, vol. 16, no. 5, pp. 1023–1032, 2022.
- [3] M. El-Shimy and H. Bassiouni, "Reactive power compensation in PV systems using FACTS devices," *Renewable Energy*, vol. 178, pp. 620–630, 2021.
- [4] S. Patel and V. Shah, "Hysteresis current controlled STATCOM for PV power quality enhancement," *International Journal of Electrical Power & Energy Systems*, vol. 146, pp. 108680, 2023.
- [5] J. Lee and K. Park, "Harmonic mitigation in grid-connected solar PV systems," *Energy Conversion and Management*, vol. 255, pp. 115307, 2022.
- [6] T. Nguyen and D. Vo, "Voltage regulation in high PV penetration distribution systems using STATCOM," *IEEE Transactions on Smart Grid*, vol. 15, no. 2, pp. 2145–2154, 2024.
- [7] R. Singh and A. Yadav, "Performance analysis of STATCOM with battery energy storage for PV systems," *Journal of Energy Storage*, vol. 63, pp. 106987, 2023.
- [8] L. Wang and X. Chen, "Control strategies for power quality improvement in solar PV grids," *Sustainable Energy Technologies and Assessments*, vol. 53, pp. 102511, 2022.
- [9] S. Rao and N. Kulkarni, "Impact of STATCOM on power factor correction in PV systems," *International Journal of Renewable Energy Research*, vol. 11, no. 4, pp. 1850–1858, 2021.
- [10] M. Hassan and F. Alotaibi, "Grid code compliance of solar PV systems using STATCOM," *Electric Power Systems Research*, vol. 226, pp. 109457, 2024.